

CERTIFICATE

EC-Type examination certificate 7017-14

Manufacturer : Inepro Metering BV
Contact person : D. van der Vaart
Address : Pondweg 7
Postal code, Place : 2153PK, Nieuw-Vennep
Country : The Netherlands

Production site : Zhejiang Yongtailong Electronic Co., Ltd.
Address : No. 320 Tongsheng Road, Tongxiang
Postal code, Place : 314500, Jiaxing City, Zhejiang
Country : China

Instrument : Electronic single-phase two-wire energy meter
Direct connected

Mark - Type : PRO1-S, PRO1-2T, PRO1-Mb and PRO1-Mod
Register : LCD
Accuracy Class : 1 / B
Measurement range : 230 V
5(45) A
50 Hz
10000 imp./kWh

Temperature range : -25 .. 55 °C
Use : Indoor
Protection Class : II
Environmental class : M1, E1
Registry method : Programmable

The energy meter meets the requirements of Directive 2004/22/EC of the European parliament and the council of 31 March 2004 on measuring instruments.

Certification was based on compliance with the following harmonised standards:


EN 50470-1 (2006) : Electricity metering equipment (a.c.)-part 1: General requirements, tests and test conditions - Metering equipment (class indexes A, B and C)
EN 50470-3 (2006) : Electricity metering equipment (a.c.)-part 3: Particular requirements - Static meters for active energy (class indexes A, B and C)

Valid until : 16 July 2024

Based on a non-recurrent examination.

The results are recorded in the following annex: test report 72141340-TIC 7017-14.

KEMA Nederland B.V.
Arnhem, 16 July 2014


ing. M. Achterkamp
Certification manager
Notified body number 2290


ing. S.A.M. Verhoeven
Business Line Director Testing, Inspections & Certification

The investigation reported here does not confer any right to use an approbation mark granted by DNV KEMA.

Integral publication of this certificate and adjoining reports is allowed.
This certificate is issued provided that neither DNV KEMA nor the RvA assumes any liability.