



EU-type examination certificate

Number **T12229** revision 1
Project number 2432096
Page 1 of 1

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Inepro Metering BV
Pondweg 7
2153 PK Nieuw Vennepe
The Netherlands

Measuring instrument A static **Active Electrical Energy Meter**

Type : 2PU CT

Manufacturer's mark or name : Inepro

Reference voltage : 230V; 3x230/400 V

Reference current : 1 A

Destined for the measurement of : electrical energy, in a
- three-phase four-wire network
- three-phase three-wire network
- two-phase three-wire network
- single-phase two-wire network

Accuracy class : A or B

Environment classes : M1 / E2

Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:
– Description T12229 revision 1;
– Documentation folder T12229-2.

Valid until 15 October 2031

Remark This revision replaces previous revision(s), including for its documentation folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**
20 October 2021

Certification Board

NMI Certin B.V.
Thijssseweg 11
2629 JA Delft
The Netherlands
T +31 88 636 2332
certin@nmi.nl
www.nmi.nl

This document is issued under the provision that no liability is accepted and that the manufacturer shall indemnify third-party liability.

The designation of NMI Certin B.V. as Notified Body can be verified at <http://ec.europa.eu/growth/tools-databases/nando/>

Reproduction of the complete document only is permitted.

This document is digitally signed and sealed. The digital signature can be verified in the blue ribbon at the top of the electronic version of this certificate.

