

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Inepro Metering BV
Pondweg 7
2153 PK Nieuw Vennep
The Netherlands

Measuring instrument A static **Active Electrical Energy Meter**

Type	: 4PS, 4PU
Manufacturer's mark or name	: Inepro
Reference voltage	: 230V; 3x230/400 V
Reference current	: 5 A
Destined for the measurement of	: electrical energy, in a - three-phase four-wire network - three-phase three-wire network - two-phase three-wire network - single-phase two-wire network
Accuracy class	: A or B
Environment classes	: M1 / E2
Temperature range	: -40 °C / +70 °C

Further properties are described in the annexes:
– Description T12050 revision 0;
– Documentation folder T12050-1.

Valid until 22 February 2031

Issuing Authority **NMI Certin B.V., Notified Body number 0122**
22 February 2021

Certification Board

NMI Certin B.V.
Thijsseweg 11
2629 JA Delft
The Netherlands
T +31 88 636 2332
certin@nmi.nl
www.nmi.nl

This document is issued under the provision that no liability is accepted and that the manufacturer shall indemnify third-party liability.

The designation of NMI Certin B.V. as Notified Body can be verified at <http://ec.europa.eu/growth/tools-databases/nando/>

Reproduction of the complete document only is permitted.

This document is digitally signed and sealed. The digital signature can be verified in the blue ribbon at the top of the electronic version of this certificate.

1 General information about the instrument

All properties of the static active electrical energy meter, whether mentioned or not, shall not be in conflict with the legislation.

1.1 Essential parts

Description	Document	Remarks
measuring sensor - 4PS - 4PU	12050/0-06 12050/0-07	
printed circuit board - 4PS - 4PU	12050/0-14; 12050/0-15; 12050/0-16 12050/0-17; 12050/0-18; 12050/0-19	All parts of the printed circuit boards are essential, except the components which are related to parts as described in paragraph 1.4 or 1.6.

1.2 Essential characteristics

- 1.2.1 See EU-type examination certificate T12050 revision 0 and the characteristics mentioned below.
- 1.2.2 Approved meter types : 4PS and 4PU
- 1.2.3 Frequency : 50 Hz or 60 Hz
- 1.2.4 Meter constant : 10.000 imp./kWh
- 1.2.5 Number of registers : max. 8
- 1.2.6 Error messages : see document: 12050/0-13
- 1.2.7 Registration method : The following registration methods are allowed:
- measurement of import and export energy by means of summation by sign (sum of import energy per phase and sum of export energy per phase);
 - measurement of energy as the sum of import and export (absolute import energy + absolute export energy);
- 1.2.8 Phase sequence : the meter is not sensitive to the direction of the applied phase sequence.
- 1.2.9 Export energy : the meter is capable of measuring energy in 2 directions.
The meter can also be used with 2 phases loaded with import energy and 1 phase loaded with export energy.
- 1.2.10 Software specification (refer to WELMEC 7.2):
- Software type P;
 - Risk Class C;
 - Extension L, S, while D and T are not applicable.

Software version	Identification number (checksum)	Remarks
V118	27325923	

The software version is displayed at start-up and in the display sequence.

1.3 Essential shapes

1.3.1 The nameplate is bearing at least, good legible, the information as mentioned in the regulations on energy meters. An example of the markings is shown in documents no. 12050/0-02 and 12050/0-03

1.3.2 Sealing: see chapter 2.

1.3.3 The registration observation is executed by means of a LED.

1.4 Conditional parts

1.4.1 Terminal block

The connections for the current cables on the terminal block have a diameter of at least 7 mm. The cables are connected with the terminal WAGO terminal block. See documents no. 12050/0-10 and 12050/0-11.

1.4.2 Housing

The meter has got a dustproof housing, which has sufficient tensile strength. The cover is made of synthetic material. An example of the housing is presented in document no.12050/0-04 and 12050/0-05.

1.4.3 Terminal cover

The terminal cover is made of synthetic material.

1.4.4 Register

The quantity of measured energy is presented by means of a display with at least 6 elements. The way of presentation is described in document no. 12050/0-12. For test purposes an indication with a least significant element of at least 0,01 kWh is available.

1.4.5 Tariff control

When the meter is provided with more than one register, a tariff control is available by means of tariff inputs, whereby the EMC-requirements are fulfilled as described in Annex V of Directive 2014/32/EU.

1.4.6 Optical communication

The meter is provided with optical communication. Via the communication no legally relevant data can be altered.

1.5 Conditional characteristics

- 1.5.1 Maximum current:
 smaller than or equal to 65. A, and at least 5 times higher than the reference current.

Terminal block:

Maximum current	Document no.	Remarks
65A	12050/0-10 and 12050/0-11	WAGO terminal blocks (no screws)

- 1.5.2 Minimum current: 0,25A

1.6 Non-essential parts

- 1.6.1 Pulse output

2 Seals

Meter sealed with void sticker seals, the meter terminal covers have space for 2 utility seals. An example of the sealing location is presented in document no. 12050/0-08 and 12050/0-09.

3 Conditions for conformity assessment according to module D or F

The influence factors for temperature, frequency and voltage, which are necessary to perform the conformity assessment according to module D or F, are presented in Annex 1, belonging to this EU-type examination certificate.
 Based on the WELMEC 11.1, section 2.5.6, the sum of the square values is presented.

Model 4PS:

Current	Power factor	-40°C [%]	-25°C [%]	-10°C [%]	+5°C [%]	+23°C [%]	+40°C [%]	+55°C [%]	+70°C [%]
I _{min}	1	0,7	0,5	0,4	0,2	0,2	0,3	0,3	0,2
I _{tr}	1	0,7	0,5	0,4	0,2	0,2	0,3	0,3	0,2
	0,5 ind. 0,8 cap.	0,6 0,6	0,5 0,5	0,4 0,4	0,2 0,2	0,2 0,2	0,3 0,3	0,3 0,3	0,2 0,2
I _{tr} phase R	1	0,8	0,6	0,4	0,2	0,2	0,3	0,4	0,0
	0,5 ind.	0,8	0,6	0,4	0,2	0,2	0,2	0,4	0,0
I _{tr} phase S	1	0,5	0,4	0,3	0,2	0,2	0,2	0,2	0,2
	0,5 ind.	0,5	0,4	0,3	0,2	0,2	0,3	0,3	0,2
I _{tr} phase T	1	0,7	0,6	0,5	0,3	0,3	0,4	0,4	0,3
	0,5 ind.	0,7	0,5	0,4	0,3	0,3	0,3	0,4	0,3
10 I _{tr}	1	0,6	0,5	0,4	0,2	0,2	0,3	0,3	0,2
	0,5 ind.	0,6	0,5	0,3	0,2	0,2	0,2	0,3	0,1
	0,8 cap.	0,7	0,5	0,4	0,2	0,2	0,2	0,3	0,2
10 I _{tr} phase R	1	0,8	0,6	0,4	0,2	0,2	0,3	0,3	0,0
	0,5 ind.	0,6	0,4	0,2	0,0	0,3	0,5	0,5	0,0
10 I _{tr} phase S	1	0,5	0,4	0,3	0,2	0,2	0,2	0,2	0,2
	0,5 ind.	0,4	0,3	0,2	0,2	0,2	0,3	0,3	0,2
10 I _{tr} phase T	1	0,7	0,6	0,5	0,4	0,3	0,3	0,4	0,3
	0,5 ind.	0,9	0,8	0,6	0,5	0,3	0,3	0,3	0,3
I _{max}	1	0,8	0,6	0,4	0,2	0,2	0,3	0,3	0,2
	0,5 ind.	0,9	0,6	0,4	0,3	0,2	0,3	0,4	0,2
	0,8 cap.	0,9	0,7	0,5	0,3	0,2	0,3	0,3	0,2
I _{max} phase R	1	1,0	0,8	0,5	0,3	0,3	0,4	0,5	0,2
	0,5 ind.	0,8	0,6	0,4	0,3	0,5	0,5	0,6	0,3
I _{max} phase S	1	0,8	0,6	0,4	0,3	0,3	0,3	0,3	0,3
	0,5 ind.	0,6	0,5	0,5	0,5	0,6	0,6	0,7	0,5
I _{max} phase T	1	1,0	0,8	0,6	0,4	0,2	0,2	0,3	0,2
	0,5 ind.	1,1	0,9	0,7	0,4	0,2	0,1	0,1	0,1